



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME SPRING VALLEY LAKE COUNTRY CLUB				DATE 5/28/2013	SIGNATURE <i>John Ramos</i>
LOCATION 13229 SPRING VALLEY LAKE PKWY, VICTORVILLE, CA 92392				REINSPECTION DATE 6/11/2013	PERMIT EXPIRATION 12/31/2013
MAILING ADDRESS 7070 SVL BOX, VICTORVILLE CA 92392				REHS John Ramos	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT					
FA # FA0006828	PR # PR0014767	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Spa
TIME IN 1:21 PM	TIME OUT 2:19 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 13 - Permit Suspended / Facility Closed

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

86

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	104.0
observed flow (gpm)	30
required flow (gpm)	35
volume (gal)	791
area (sq ft)	47
occupancy	4

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Comply by: 6/11/2013
Not In Compliance
Violation Reference - HSC

Inspector Comments: Permit is suspended and spa ordered closed due to high chlorine levels and low pH. Contact John Ramos at (760) 995-8148 when spa is ready to reopen.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS
4

Comply by: 6/11/2013
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed the chlorine level above 15 ppm. Ensure to maintain free chlorine between 1.5 to 10.0 ppm. Spa closed due to high chlorine levels.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K406 Water Quality - Critical - pH High/Low

⚠ CRITICAL ⚠

POINTS
4

Comply by: 6/11/2013
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed pH level below 7.0. Maintain pH levels between 7.2 and 8.0. Spa closed due to low pH levels.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid level above 100 ppm. Ensure to keep cyanuric acid below 100 ppm.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME SPRING VALLEY LAKE COUNTRY CLUB	DATE 5/28/2013	SIGNATURE
LOCATION 13229 SPRING VALLEY LAKE PKWY, VICTORVILLE, CA 92392	REHS John Ramos	

36K460 Skimmers - Requirements

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no check valve installed. Install a check valve.
	Not In Compliance	
Violation Reference - CCR - 65533, 3136B		

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

36K462 Plumbing - Backflow Protection

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed waste discharge line plumbed directly to sewer without an air gap. Discharge all waste water to sewer with an air gap.
	Not In Compliance	
Violation Reference - CCR - 3141B, 3118B		

Violation Description: There shall be no direct connection between any potable water supply system and the pool or its piping system unless protected by a backflow prevention device in accordance with Chapter 6 of the California Plumbing Code. There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system. Potable water outlets with hose attachments shall be protected by a nonremovable hose bibb backflow preventer, a nonremovable hose bibb vacuum breaker, or by an atmospheric vacuum breaker.

Overall Inspection Comments

Health permit suspended and pool closed due to low pH & high chlorine. Notice of Closure posted. Do not remove sign or reopen pool without authorization from Environmental Health.

If you have any questions contact John Ramos at (800) 442-2283.
Our office has moved to 15900 Smoke Tree Street, Hesperia, CA 92345.

Summary:

Influent: 14 psi

Photo Attachments:

No Photo Attachments