



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME AMBASSADOR HOTEL					DATE 5/28/2013	SIGNATURE <i>Veronica Vazquez</i>	
LOCATION 15494 PALMDALE RD, VICTORVILLE, CA 92392					REINSPECTION DATE 6/11/2013	PERMIT EXPIRATION 11/30/2013	
MAILING ADDRESS 8502 E CHAPMAN AV UNIT 614, ORANGE CA 92869					REHS Veronica Vazquez		
FA # FA0004497	PR # PR0013983	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: pool		
TIME IN 1:53 PM	TIME OUT 2:52 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 13 - Permit Suspended / Facility Closed		

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

88

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	0
required flow (gpm)	220
volume (gal)	105,673
area (sq ft)	2,975
occupancy	146

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: Pool is hereby closed due to main drain not visible in pool.

Notice of closure sign posted. Operator locked pool gate.

Do not remove or reopen pool without authorization from Environmental Health.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K408 Water Quality - Critical - Clarity

⚠ CRITICAL ⚠

POINTS
4

Comply by: 5/30/2013
Not In Compliance
Violation Reference - CCR - 65527, 65543

Inspector Comments: Ensure water of pool is kept sufficiently clear so that the main drain of the pool is visible at all times. Unable to see main drain from deck area.

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. Under no circumstances shall the pool be used if the main drain is not clearly visible from the deck. The water of every wading pool shall be kept sufficiently clear so that the bottom of the wading pool will be visible at all times.

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Ensure cyanuric acid concentration in the pool does not exceeded 100 ppm. Observed cyanuric acid above 100ppm in pool.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME AMBASSADOR HOTEL	DATE 5/28/2013	SIGNATURE <i>Veronica Vazquez</i>
LOCATION 15494 PALMDALE RD, VICTORVILLE, CA 92392	REHS Veronica Vazquez	

36K428 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR 24 - 3120B	Inspector Comments: The following shall be posted: Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK." d) An illustrated diagram with text at least 1/4 inch high of artificial respiration <u>Observed these signs missing.</u>
---------------------------	---	--

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3125B	Inspector Comments: Ensure flow meter is in good repair to display flow rate of 220gpm. Observed broken flow meter. <u>Observed broken flow meter.</u>
---------------------------	--	---

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K468 Construction - Markings

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3110B	Inspector Comments: Ensure Pools with a maximum water depth greater than 5 feet shall have a slip resistant tile a minimum of 4 inches and not greater than 6 inches wide of a color contrasting with the background of the pool shell across the bottom of the pool where the water depth is 4 1/2 feet. <u>Observed no at 4 1/2 ft indicator to separate shallow end from deep end of 8 ft in the pool.</u>
---------------------------	--	--

Violation Description: The water depth shall be clearly marked at the following locations: maximum depth; minimum depth; each end; both sides at each end; at the break in the bottom slope between the shallow and deep portions of the pool; and along the perimeter of the pool at distances not to exceed 25 feet. Pools with a maximum water depth greater than 5 feet shall have a slip resistant tile a minimum of 4 inches and not greater than 6 inches wide of a color contrasting with the background of the pool shell across the bottom of the pool where the water depth is 4 1/2 feet. For pool water depths 6 feet and shallower no diving markers with the universal symbol of no diving shall be installed on the deck directly adjacent to the depth markers.

No markings, designs or lettering shall be permitted on the pool shell except for slip resistant lane markings, depth marking lines and safety markings.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME AMBASSADOR HOTEL	DATE 5/28/2013	SIGNATURE 
LOCATION 15494 PALMDALE RD, VICTORVILLE, CA 92392	REHS Veronica Vazquez	

Observed pool gate locked at time of inspection. Operator had to open gate to inspect.

The following signs will be required by next year

- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures
- The emergency telephone number of the nearest emergency services and the name and street address of the pool facility.
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating , "KEEP CLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.

Call Veronica Vazquez at 1 800-442-2283 with any questions.

Photo Attachments:

No Photo Attachments