



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME SUNSET INNS				DATE 5/30/2013	SIGNATURE
LOCATION 15765 MOJAVE DR, VICTORVILLE, CA 92392				REINSPECTION DATE 11/30/2013	PERMIT EXPIRATION 12/31/2013
MAILING ADDRESS 15765 MOJAVE DR, VICTORVILLE CA 92392				REHS Veronica Vazquez	
FA # FA0006179	PR # PR0015950	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: pool
TIME IN 10:55 AM	TIME OUT 11:24 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

88
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	0
required flow (gpm)	30
volume (gal)	10,788
area (sq ft)	360
occupancy	18

36K428 Safety - Safety Signs

POINTS	Compliance Date: Not Specified
2	Not In Compliance
	Violation Reference - CCR 24 - 3120B

Inspector Comments: Ensure occupancy of 18 is posted on safety sign. Observed occupancy sign empty.

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K430 Safety - Equipment/First Aid Kit

POINTS	Compliance Date: Not Specified
2	Not In Compliance
	Violation Reference - CCR - 65539

Inspector Comments: Ensure body hook is accessible. Observed body hook behind to mattresses in pool area.

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

36K448 Equipment - Flow Meter

POINTS	Compliance Date: Not Specified
2	Not In Compliance
	Violation Reference - CCR - 3125B

Inspector Comments: Ensure flow meter is in good repair to show 30 gpm (gallons per minute.) Observed flow meter at zero gpm.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME SUNSET INNS	DATE 5/30/2013	SIGNATURE
LOCATION 15765 MOJAVE DR, VICTORVILLE, CA 92392		REHS Veronica Vazquez

36K454 Maintenance - Cleanliness

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Ensure not to allow excessive debris in the pool. Observed excessive dust debris inside the pool.
	Not In Compliance	
	Violation Reference - CCR - 65533	

Violation Description: Floating scum, sputum or debris shall not be allowed to accumulate in the pool. The bottom and sides of the pool shall be cleaned as often as necessary to be kept in a clean condition. The sides and bottom of pools, decks and other surfaces shall be kept free of slime and algae.

36K460 Skimmers - Requirements

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Ensure not to put chlorine tablets in skimmer. Observed chlorine tablet in pool skimmer.
	Not In Compliance	
	Violation Reference - CCR - 65533, 3136B	

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

36K476 Decking - Requirements

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Ensure pool deck has is unobstructed 4-foot wide around the pool. Observed table an plants obstructing deck area along the shallow end of pool
	Not In Compliance	
	Violation Reference - CCR - 3114B	

Violation Description: A minimum continuous and unobstructed 4-foot wide slip resistant, cleanable, nonabrasive deck area of concrete or like material shall be provided flush with the top of the pool coping extending completely around the pool, and the deck area shall further extend 4 feet both sides and rear of any diving board, fixed disabled access assistance device or slide and their appurtenances. Deck shall be maintained in good repair.

Overall Inspection Comments

The following signs will be required by next year:

- a) An illustrated diagram with text at least 1/4 inch high of CPR procedures.
- b) The telephone number of the nearest emergency services and the name and street address of the pool facility.
- c) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- d) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.

Call Veronica Vazquez at 1 800-442-2283 with any questions.

Photo Attachments:

No Photo Attachments