



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME LOS RANCHOS				DATE 6/3/2013	SIGNATURE <i>[Signature]</i>
LOCATION 20843 WAALEW RD, APPLE VALLEY, CA 92307				REINSPECTION DATE 12/03/2013	PERMIT EXPIRATION 2/28/2014
MAILING ADDRESS 20843 WAALEW RD, APPLE VALLEY, CA 92307				REHS Dawn LaFlower	
FA # FA0004537	PR # PR0016316	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: east spa
TIME IN 11:50 AM	TIME OUT 12:45 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

82
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	104.0
observed flow (gpm)	0
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K402 Water Quality - Critical - Lack of Disinfectant

CRITICAL

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Maintain free chlorine between 1.5-10.0 ppm when spa is available for use.
	Not In Compliance	Observed free chlorine measuring 0.5 ppm. corrected to 1.5 ppm.
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K426 Safety - Emergency Shut-Off Switch

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Immediately provide an Emergency Shut off Switch for spa.
	Not In Compliance	Observed no Emergency Shut off Switch sign.
	Violation Reference - CCR - 3138B	

Violation Description: A clearly labeled emergency shut off switch for the control of both the recirculation system and the aeration and/or jet system shall be installed adjacent to the spa pool.

36K428 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME LOS RANCHOS	DATE 6/3/2013	SIGNATURE
LOCATION 20843 WAALEW RD, APPLE VALLEY, CA 92307	REHS Dawn LaFlower	

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Provide labeling on recirculation piping that clearly shows the direction of flow. Observed the direction of flow no labeled on recirculation piping.
	Violation Reference - HSC - 3120B, 3132B, 3141B	Provide a minimum 1" air gap between wastewater pipe and sanitary sewer. Observed pipes from separation tank laying on ground to sanitary sewer.

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Repair/replace flow meter and maintain a flow rate of 65 gpm.
	Violation Reference - CCR - 3125B	Observed flow meter not functioning.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K456 Maintenance - Spa/Pool Area - Pump Room

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Provide test kit for daily chemical testing. Observed old test kit.
	Violation Reference - CCR - 65535	Ensure to keep daily records of of chemical readings and maintenance procedures. Observed no daily records.

Violation Description: All parts of the pool and related pool facilities and equipment shall be maintained in good repair. Floors shall be kept free from cracks and other defects. Walls, ceilings, partitions, doors and similar surfaces and equipment shall be refinished in a manner acceptable to DEHS as often as necessary to be kept in a state of good repair. Hoses shall be provided for regular flushing and cleaning. The whole pool area shall be kept clean, sanitary and free of litter and vermin.

36K460 Skimmers - Requirements

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Provide weir for skimmer.
	Violation Reference - CCR - 65533, 3136B	Observed missing weir for skimmer.

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

36K466 Structure - Pool Shell

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Replaster shell prior to next pool season.
	Violation Reference - CCR - 3108B	Observed chipping.

Violation Description: The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME LOS RANCHOS	DATE 6/3/2013	SIGNATURE
LOCATION 20843 WAALEW RD, APPLE VALLEY, CA 92307	REHS Dawn LaFlower	

36K429 Safety - Notification - New Sign Requirements

POINTS NA	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments