



County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

|  |                            |                                |                              |                                       |   |
|--|----------------------------|--------------------------------|------------------------------|---------------------------------------|---|
| FACILITY NAME<br><b>EUCLID ARMS APARTMENTS</b>                 |                            |                                |                              | DATE<br><b>6/4/2013</b>               | SIGNATURE   |
| LOCATION<br><b>811 ORCHID CT, UPLAND, CA 91786</b>             |                            |                                |                              | REINSPECTION DATE<br><b>6/18/2013</b> | PERMIT EXPIRATION<br><b>5/31/2013</b>               |
| MAILING ADDRESS<br><b>2849 S MONTERRY AV, ONTARIO CA 91761</b> |                            |                                |                              | REHS<br><b>Shannon Johnson</b>        |   |
| FA #<br><b>FA0008560</b>                                       | PR #<br><b>PR0014446</b>   | SR #<br><b>Not Specified</b>   | CO #<br><b>Not Specified</b> | PE<br><b>3601</b>                     | PROGRAM IDENTIFIER: pool                            |
| TIME IN<br><b>4:32 PM</b>                                      | TIME OUT<br><b>4:45 PM</b> | CONTACT<br><b>Not Captured</b> |                              |                                       | SERVICE: 001 - Inspection - Routine                 |
|  |                            |                                |                              |                                       | RESULT: 05 - Corrective Action / Follow up Required |
|  |                            |                                |                              |                                       | ACTION: 13 - Permit Suspended / Facility Closed     |

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**100**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

|                   |
|-------------------|
| Ideal             |
| In Compliance     |
| Not in Compliance |



|                     |         |
|---------------------|---------|
| temperature (F)     | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 57      |
| volume (gal)        | 20,345  |
| area (sq ft)        | 544     |
| occupancy           | 27      |

**36K995 Permit - Suspension**

**⚠ CRITICAL ⚠**

**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

Inspector Comments: Due to no AB1020 equalizer line cover present.

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K990 Survey Inspection**

**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - SBCC - SBC Policy

Inspector Comments: This pool was closed to residents at the time of this inspection. A complete routine inspection will be conducted after the AB1020 issue is resolved.

**Violation Description:** A survey inspection was conducted on this date.

**36K488 AB 1020 - Critical - Non-Compliant Pool/Spa**

**⚠ CRITICAL ⚠**

**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR

Inspector Comments: Observed no AB1020 equalizer line cover within this pool.

**Violation Description:** Pool or spa is in violation of State Assembly Bill 1020, the Anti-Entrapment Devices and System Law for Public Swimming Pools. The compliance date of July 1, 2010 has passed. Compliance with AB 1020 is required. Health Permit is suspended, and the pool/spa is posted closed at this time. A drained pool/spa shall remain closed and secured until plans have been submitted to and approved by DEHS and all related construction finalized. Pool/spa shall meet all current health code requirements including compliance with AB 1020. If pool/spa is to be demolished, approval from Building and Safety must be obtained. Submit copy of finalized building permit to EHS for permit inactivation.

**Overall Inspection Comments**

Contact plan check of this department prior to installation of the AB1020 equalizer cover to ensure the proper cover is installed.

This pool is to remained closed until all repairs have been made.

**Photo Attachments:**

No Photo Attachments