



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

| | | | | | |
|--|-----------------------------|--------------------------------|------------------------------|--|--|
| FACILITY NAME 24 HOUR FITNESS | | | | DATE 6/4/2013 | SIGNATURE |
| LOCATION 17204 SLOVER AV, FONTANA, CA 92337 | | | | REINSPECTION DATE 12/04/2013 | PERMIT EXPIRATION 3/31/2014 |
| MAILING ADDRESS PO BOX 2409, CARLSBAD CA 92677 | | | | REHS Chris Nwadike | |
| FA # FA0026752 | PR # PR0035076 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: #1 pool |
| TIME IN 10:25 PM | TIME OUT 11:23 PM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required |
| | | | | | ACTION: 01 - No Further Action Required |

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

SCORE

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | 82.0 |
| observed flow (gpm) | 0 |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

36K430 Safety - Equipment/First Aid Kit

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed very short rope attachment to the life ring. Provide rope attachment long enough to span the width of the pool. |
| | Not In Compliance | |
| | Violation Reference - CCR - 65539 | |

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

36K448 Equipment - Flow Meter

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed stuck flow meter. Repair or replace. |
| | Not In Compliance | |
| | Violation Reference - CCR - 3125B | |

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

| | | |
|---|------------------------------|---------------|
| FACILITY NAME 24 HOUR FITNESS | DATE 6/4/2013 | SIGNATURE |
| LOCATION 17204 SLOVER AV, FONTANA, CA 92337 | REHS Chris Nwadike | |

36K429 Safety - Notification - New Sign Requirements

| | | |
|----------------------------|--------------------------------------|----------------------------|
| POINTS NA | Compliance Date: Not Specified | Inspector Comments: |
| | Not In Compliance | |
| | Violation Reference - CCR 24 - 3120B | |

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments