



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME MOUNTAIN VISTA APTS					DATE 6/5/2013	SIGNATURE <i>See Pool Report</i>	
LOCATION 15450 NISQUALLY RD, VICTORVILLE, CA 92392					REINSPECTION DATE 12/05/2013	PERMIT EXPIRATION 5/31/2013	
MAILING ADDRESS 15450 NISQUALLY RD, VICTORVILLE, CA 92392					REHS John Ramos		
FA # FA0006539	PR # PR0015502	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: South Spa (by Office)		
TIME IN 10:23 AM	TIME OUT 10:55 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.



temperature (F)	103.0
observed flow (gpm)	No Data
required flow (gpm)	43
volume (gal)	1,276
area (sq ft)	79
occupancy	7

36K406 Water Quality - Critical - pH High/Low



POINTS
4

Comply by: 6/19/2013
Complied on 6/5/2013
Violation Reference - CCR - 65529

Inspector Comments: Observed pH level below 7.0. Maintain pH levels between 7.2 and 8.0. Corrected to 7.2.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Observed stuck flow meter. Repair or replace.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K429 Safety - Notification - New Sign Requirements

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR 24 - 3120B

Inspector Comments: Observed outdated safety signs and should be replaced within 1 year.

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME MOUNTAIN VISTA APTS	DATE 6/5/2013	SIGNATURE <i>See Pool Report</i>
LOCATION 15450 NISQUALLY RD, VICTORVILLE, CA 92392	REHS John Ramos	

Overall Inspection Comments

Correct the above noted violations.

If you have any questions contact John Ramos at (800) 442-2283.
Our office has moved to 15900 Smoke Tree Street, Hesperia, CA 92345.

Photo Attachments:

No Photo Attachments