



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**




(800) 442-2283

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>LOMA LINDA HOA AKA CRESTA LINDA</b>				DATE <b>6/5/2013</b>	SIGNATURE <i>Send to Has</i>
LOCATION <b>1520 COULSTON, SAN BERNARDINO, CA 92408</b>				REINSPECTION DATE <b>11/05/2013</b>	PERMIT EXPIRATION <b>4/30/2014</b>
MAILING ADDRESS <b>PO BOX 3589, MISSION VIEJO CA 92690</b>				REHS <b>Marilyn Krichbaum</b>	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: Spa	
FA # <b>FA0006008</b>	PR # <b>PR0013705</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	SERVICE: 003 - Inspection - Follow Up Inspection
TIME IN <b>9:35 AM</b>	TIME OUT <b>9:55 AM</b>	CONTACT <b>Not Captured</b>			RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 15 - Permit Reinstated / Facility Re-opened

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

<b>Ideal</b>
<b>In Compliance</b>
<b>Not in Compliance</b>



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	6

**36K994 Reinspection**

**POINTS**  
**NA**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC

**Inspector Comments:** Reinspection: Provide this dept with a key to the spa equipment room.

Observed a chlorine level of 10ppm, ph 7.4, cyanuric acid level of 70. Chemicals are within the law requirements. Spa can be reopened. Health permit is reinstated.

Repair nonfunctioning spa light.

Repair nonfunctioning flowmeter.

Replace the missing heater for the spa as noted on last years report. Repair/replace nonfunctioning aerator as noted on last years report. Provide compliance date for these violations. Call me at 1-800-442-2283, otherwise a hearing will be scheduled.

Repair/replace nonfunctioning aerator as noted on last years report

**Violation Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments