




County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dehs

| | | | | | |
|--|-----------------------------|--------------------------------|------------------------------|--|--|
| FACILITY NAME LOMA LINDA VILLAGE HOA | | | | DATE 6/5/2013 | SIGNATURE <i>Sent to HOA</i> |
| LOCATION 10196 AMBROSIA WY, SAN BERNARDINO, CA 92408 | | | | REINSPECTION DATE 11/05/2013 | PERMIT EXPIRATION 3/31/2014 |
| MAILING ADDRESS PO BOX490, UPLAND CA 91785 | | | | REHS Marilyn Krichbaum | |
| <input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT | | | | PROGRAM IDENTIFIER: Spa | |
| FA # FA0004653 | PR # PR0015255 | SR # Not Specified | CO # Not Specified | PE 3601 | SERVICE: 003 - Inspection - Follow Up Inspection |
| TIME IN 10:30 AM | TIME OUT 10:55 AM | CONTACT Not Captured | | | RESULT: 03 - Corrective Action / No Follow up Required |
| | | | | | ACTION: 01 - No Further Action Required |

RECREATIONAL HEALTH - PUBLIC POOL/SPA



| | |
|---------------------|---------|
| temperature (F) | 81.0 |
| observed flow (gpm) | 40 |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | 7 |

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

| | | |
|---------------------------|---|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed that the wastewater from the separation tank drains to the ground. Plumb wastewater from separation tank indirectly to the sewer. Provide the direction of the flow of the water thru the recirculation system on all of the piping. |
| | Violation Reference - HSC - 3120B, 3132B, 3141B | |

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K482 Restrooms - Toilet Facilities - Showers - Drinking Fountain

| | | |
|---------------------------|---|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Could not access the restrooms. Provide this dept with keys to the pool area, equipment room and restrooms as noted on last years report. Call Marilyn at 1-800-442-2283. Make the necessary repairs. Provide hot water to the shower. |
| | Violation Reference - CCR - 65535, 65551, 3117B | |

Violation Description: Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate- cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices. Showers and lavatories shall be provided with hot and cold water faucets.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

| | | |
|---|---------------------------|---------------------------------|
| FACILITY NAME LOMA LINDA VILLAGE HOA | DATE 6/5/2013 | SIGNATURE <i>Sent to HOA</i> |
| LOCATION 10196 AMBROSIA WY, SAN BERNARDINO, CA 92408 | REHS Marilyn Krichbaum | |

36K429 Safety - Notification - New Sign Requirements

| | | |
|---------------------|--------------------------------------|---|
| POINTS NA | Compliance Date: Not Specified | Inspector Comments: Post the new signs as noted on the pool report. |
| | Not In Compliance | |
| | Violation Reference - CCR 24 - 3120B | |

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments