



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME NORTHSHORE RV RESORT INC					DATE 5/31/2013	SIGNATURE <i>Ch paper report</i>	
LOCATION 3408 RIVER RD, NEEDLES, CA 92363					REINSPECTION DATE 11/30/2013	PERMIT EXPIRATION 1/31/2014	
MAILING ADDRESS 3408 RIVER RD, NEEDLES, CA 92363					REHS Veronica Vazquez		
FA # FA0005373	PR # PR0015083	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: spa		
TIME IN 10:20 AM	TIME OUT 10:34 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

98

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	103.0
observed flow (gpm)	No Data
required flow (gpm)	44
volume (gal)	1,324
area (sq ft)	80
occupancy	8

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Ensure flow meter is in good repair. Observed flow meter at zero gpm.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

Overall Inspection Comments

These signs will be required by next year:

- a) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- b) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- c) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- d) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.

Call Veronica Vazquez with questions at (800) 442-2283.

Photo Attachments:

No Photo Attachments