



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME EUREKA MANOR					DATE 6/7/2013	SIGNATURE	
LOCATION 1525 E EUREKA ST, SAN BERNARDINO, CA 92404					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 3/31/2014	
MAILING ADDRESS 4900 SANTA ANITA AV UNIT 2C, EL MONTE CA 91731					REHS Chaz Harrison		
FA # FA0008381	PR # PR0015660	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: spa		
TIME IN 11:13 AM	TIME OUT 11:32 AM	CONTACT Not Captured			SERVICE: 038 - Public Pool/Spa - Rescore Inspection		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 14 - Permit Suspd / Facility Closed fencing iss		

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

86

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	59
volume (gal)	1,770
area (sq ft)	94
occupancy	9

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments:

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed no chlorine detected at time of inspection; Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K426 Safety - Emergency Shut-Off Switch

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3138B

Inspector Comments: Emergency shut off switch not properly operating. Repair/replace.

Violation Description: A clearly labeled emergency shut off switch for the control of both the recirculation system and the aeration and/or jet system shall be installed adjacent to the spa pool.



COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dehs

(800) 442-2283

Table with 3 columns: FACILITY NAME (EUREKA MANOR), DATE (6/7/2013), SIGNATURE (Chaz Harrison), LOCATION (1525 E EUREKA ST, SAN BERNARDINO, CA 92404), REHS (Chaz Harrison)

36K428 Safety - Safety Signs

Table with 2 columns: POINTS (2), Compliance Date: Not Specified, Not In Compliance, Violation Reference - CCR 24 - 3120B

Inspector Comments: "911" Emergency number
Artificial Respiration Procedures (rescue breathing)
Danger: Gaseous Oxidizer Chlorine (required for pools with chlorine gas with the hazard ID symbol posted on the exterior door where chlorine gas is located)
No Diving Allowed (if less than 6 foot depth)
No Life Guard On Duty
No Use of Pool After Dark (for pools without sufficient lighting or missing light fixture)
Occupant capacity (not required for wading pool) In addition to the above mentioned signs, the following shall be kept on site in the spa area:
Caution/Warning sign with the following language:

- 1. Elderly persons, pregnant women, infants and those with health conditions requiring medical care should consult with a physician before entering a spa.
2. Unsupervised use by children under the age of 14 is prohibited.
3. Hot water immersion while under the influence of alcohol, narcotics, drugs, or medicines may lead to serious consequences and is not recommended.
4. Do not use alone.
5. Long exposure may result in nausea, dizziness or fainting.
Emergency Shut-off switch sign. Switch is required for recirculation only (post 1982) and for shutting down both jets and recirculation (post 1985).

Observed the following missing signs:

KEEP CLOSED - A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED" (3120B.10).

DIARRHEA - A sign in letters at least 1 inch (25 mm) high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water (3120B.11).

Ensure to install signs on the outside of the gate.

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
f) A warning sign for spa pools with "CAUTION" language.
g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K430 Safety - Equipment/First Aid Kit

Table with 2 columns: POINTS (2), Compliance Date: Not Specified, Not In Compliance, Violation Reference - CCR - 65539

Inspector Comments: Observed no life ring at time of inspection. Ensure a life ring is located near pool at all times. All swimming pools are required to provide a life ring with an outside diameter of 17 inches and a rope (at least 3/16 inches in diameter) attached that is long enough to span the widest part of the pool.

Observed no body hook. Ensure to obtain a body hook before opening pool.

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME EUREKA MANOR	DATE 6/7/2013	SIGNATURE
LOCATION 1525 E EUREKA ST, SAN BERNARDINO, CA 92404	REHS Chaz Harrison	

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no test kit. Ensure to obtain a test kit. Taylor k-2009(recommended). Observed no daily pool records on site. Ensure to maintain daily records for pool. Pool Code sec. 65523 states: "The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used." Also it states: "If cyanuric acid is used..., the cyanuric acid concentration shall be measured a minimum of once per month and records shall be kept of the results of such testing." If the pool service person is only at the site 3 days a week, there needs to be someone else to record the chlorine and pH on the other 4 days. The only way poor chemistry can be corrected is if someone knows that it is "poor."
	Not In Compliance Violation Reference - CCR - 65523, 65529	

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

36K474 Lighting - Adequate Lighting and Ventilation

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Pool and spa lights not working. Repair/replace.
	Not In Compliance Violation Reference - SBCC - 3115B, 3106B, 3121B	

Violation Description: Pools used at night shall be equipped with underwater lighting fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots. Pool deck areas and emergency egress areas shall be provided with lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Artificial lighting shall be provided at all spray ground pads which are used at night or which do not have adequate natural lighting so that all portions of the spray pad and deck may be seen easily.

Indoor pools, dressing rooms and toilet rooms shall be ventilated according to the requirements in Chapter 4 of the California Mechanical Code.

Overall Inspection Comments

Permit to remain suspended.

Photo Attachments:

No Photo Attachments