



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>SUNRIDGE PINES APARTMENTS II</b>				DATE <b>6/11/2013</b>	SIGNATURE
LOCATION <b>6592 POST PL, RANCHO CUCAMONGA, CA 91701</b>				REINSPECTION DATE <b>12/11/2013</b>	PERMIT EXPIRATION <b>12/31/2013</b>
MAILING ADDRESS <b>10505 SORRENTO VALLEY RD UNIT 300, SAN DIEGO CA 92121</b>				REHS <b>Isaac Gebreslassie</b>	
FA # <b>FA0005713</b>	PR # <b>PR0014978</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: pool - office
TIME IN <b>9:33 AM</b>	TIME OUT <b>10:00 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**94**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	80
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	16

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed cyanuric acid level at > 100 ppm. Adjust level to 100 ppm or below.

**Violation Description:** The cyanuric acid concentration in any pool shall not exceed 100 ppm.

**36K460 Skimmers - Requirements**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65533, 3136B

**Inspector Comments:** Observed weir gates missing on all skimmers

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**36K474 Lighting - Adequate Lighting and Ventilation**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - SBCC - 3115B, 3106B, 3121B

**Inspector Comments:** Observed pool lights to be inoperable. Repair/replace as needed.

**Violation Description:** Pools used at night shall be equipped with underwater lighting fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots. Pool deck areas and emergency egress areas shall be provided with lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Artificial lighting shall be provided at all spray ground pads which are used at night or which do not have adequate natural lighting so that all portions of the spray pad and deck may be seen easily.

Indoor pools, dressing rooms and toilet rooms shall be ventilated according to the requirements in Chapter 4 of the California Mechanical Code.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments