



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME EASTVIEW MANOR APTS				DATE 6/11/2013	SIGNATURE
LOCATION 2301 N MOUNTAIN AV, SAN BERNARDINO, CA 92404				REINSPECTION DATE 12/11/2013	PERMIT EXPIRATION 6/30/2013
MAILING ADDRESS 1026 S LOLITA AV, WEST COVINA CA 91791				REHS Chaz Harrison	
FA # FA0008818	PR # PR0016016	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: None
TIME IN 11:43 AM	TIME OUT 12:23 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

86

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	83
volume (gal)	30,000
area (sq ft)	800
occupancy	40

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments:

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed no chlorine detected at time of inspection; Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K406 Water Quality - Critical - pH High/Low

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed pH level at 7.0. Immediately provide pH level at 7.2-8.0. Use Soda Ash(Baking Soda) to increase the Total Alkalinity of pool.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K422 Safety - Critical - Unsafe/Hazardous Conditions

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 116040, 65545, 116049

Inspector Comments: Main drain not visible from deck. Ensure water is clear and main drain is visible.

Violation Description: Every person operating or maintaining a public swimming pool must do so in a sanitary, healthful and safe manner. Unhealthful, unsafe or unsanitary conditions include, but are not limited to, the failure to meet clarity, disinfection, pH, safety or bacteriological standards, broken glass on pool deck, electrical hazard; chemical storage.

All dry-niche light fixtures, and all underwater wet-niche light fixtures operating at more than 15 volts in public swimming pools shall be protected by a ground-fault circuit interrupter in the branch circuit, and all light fixtures in public swimming pools shall have encapsulated terminals. The ground-fault circuit interrupter shall comply with Underwriter's Laboratory standards.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME EASTVIEW MANOR APTS	DATE 6/11/2013	SIGNATURE
LOCATION 2301 N MOUNTAIN AV, SAN BERNARDINO, CA 92404	REHS Chaz Harrison	

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid level above 100 ppm. Cyanuric acid shall not exceed 100 ppm. Cyanuric acid can be lowered by slightly draining the pool/spa and adding fresh water.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments