



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME AYRES HOTEL				DATE 6/13/2013	SIGNATURE
LOCATION 4785 CHINO HILLS PKWY, CHINO HILLS, CA 91709				REINSPECTION DATE 6/27/2013	PERMIT EXPIRATION 6/30/2013
MAILING ADDRESS 355 BRISTOL ST STE A, COSTA MESA CA 92626				REHS Tin Nguyen	
FA # FA0017188	PR # PR0023205	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: SPA
TIME IN 10:18 AM	TIME OUT 10:45 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 13 - Permit Suspended / Facility Closed

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	102.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments:

-Spa permit has been suspended due to low chlorine level in spa measured at 0 ppm.
-Spa is ordered closed by Division of Environmental Health Services (DEHS) due to low chlorine level in spa measured at 0 ppm. DO NOT OPEN SPA, UNTIL AUTHORIZED BY DEHS. Noncompliance will result in future charged inspections at \$245.00 per hour.

-Contact DEHS at (800) 442-2283 when ready to re-open.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed chlorine level at 0 ppm in spa.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

Overall Inspection Comments

pH: 8.0
Chlorine: 0 ppm
CYA: 0 ppm
Flow rate: 49 gpm
Photo Attachments:
No Photo Attachments