



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME NEEDLES KOA					DATE 6/12/2013	SIGNATURE <i>Carla Samberg</i>	
LOCATION 5400 NATIONAL TRAILS HWY, NEEDLES, CA 92363					REINSPECTION DATE 12/12/2013	PERMIT EXPIRATION 12/31/2013	
MAILING ADDRESS 5400 NATIONAL TRAILS HWY, NEEDLES CA 92363					REHS Veronica Vazquez		
FA # FA0006689	PR # PR0015989	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool		
TIME IN 9:53 AM	TIME OUT 10:16 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	40
required flow (gpm)	68
volume (gal)	33,000
area (sq ft)	800
occupancy	40

36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level

POINTS	Comply by: 6/13/2013
2	Not In Compliance
	Violation Reference - CCR - 65529

Inspector Comments: a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

Observed chlorine at 0.5 ppm in the pool.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

36K414 Water Quality - Non-Critical - pH High/Low

POINTS	Comply by: 6/13/2013
2	Not In Compliance
	Violation Reference - CCR - 65529

Inspector Comments: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.
Observed pH at 7.0 in the pool.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K418 Water Quality - Cyanurates

POINTS	Comply by: 6/13/2013
2	Not In Compliance
	Violation Reference - CCR - 65529

Inspector Comments: The cyanuric acid concentration in any pool shall not exceeded 100 ppm. Observed cyanuric acid above 100ppm in the pool

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K430 Safety - Equipment/First Aid Kit

POINTS	Comply by: 6/13/2013
2	Not In Compliance
	Violation Reference - CCR - 65539

Inspector Comments: Ensure rescue poles are not less than 12 feet in length with body hooks. Observed body hook 9ft long.

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME NEEDLES KOA	DATE 6/12/2013	SIGNATURE <i>Carla Samberg</i>
LOCATION 5400 NATIONAL TRAILS HWY, NEEDLES, CA 92363	REHS Veronica Vazquez	

These signs will be required by next year:

- a) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- b) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- c) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- d) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.

-

Photo Attachments:

No Photo Attachments