



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

| | | | | | | | |
|---|-----------------------------|--------------------------------|------------------------------|-------------------|--|--|--|
| FACILITY NAME CAMP CEDAR FALLS | | | | | DATE 6/17/2013 | SIGNATURE | |
| LOCATION 3985 HWY 38 , ANGELUS OAKS, CA 92305 | | | | | REINSPECTION DATE 12/17/2013 | PERMIT EXPIRATION 12/31/2013 | |
| MAILING ADDRESS 39850 STATE HWY 38, ANGELUS OAKS CA 92305 | | | | | REHS Antonio Fields | | |
| FA # FA0007080 | PR # PR0004043 | SR # Not Specified | CO # Not Specified | PE 3632 | PROGRAM IDENTIFIER: POOL | | |
| TIME IN 10:44 AM | TIME OUT 11:24 AM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine | | |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required | | |
| | | | | | ACTION: 01 - No Further Action Required | | |




RECREATIONAL HEALTH - ORGANIZED CAMP POOL

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | 0.0 |
| observed flow (gpm) | No Data |
| required flow (gpm) | 190 |
| volume (gal) | 64,500 |
| area (sq ft) | 1,500 |
| occupancy | 75 |

36K438 Enclosure - Critical - Gates Drowning Hazard

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 3119B

Inspector Comments: Observed the gate unable to self-latch. Repair/Replace. Corrected during the inspection.

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 3120B, 3132B, 3141B

Inspector Comments: Leakage observed on the recirculation system water lines near the pumps. Repair/Replace.

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Inoperable flow meter observed. Repair/Replace. Maintain a minimum flow rate of 190 gpm.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

Overall Inspection Comments

- Influent pressure 1: 26 psi (provide backwashing as needed)
- Influent pressure 2: 28 psi (provide backwashing as needed)
- Influent pressure 3: 32 psi (provide backwashing as needed)

Photo Attachments:
No Photo Attachments