



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME YUCAIPA SWIMMING POOL					DATE 6/19/2013	SIGNATURE	
LOCATION 12385 7TH ST, YUCAIPA, CA 92399					REINSPECTION DATE 12/19/2013	PERMIT EXPIRATION 7/31/2012	
MAILING ADDRESS 34272 YUCAIPA BL, YUCAIPA CA 92399					REHS Antonio Fields		
FA # FA0006485	PR # PR0014847	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool, Primary		
TIME IN 12:07 PM	TIME OUT 12:39 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

98

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K414 Water Quality - Non-Critical - pH High/Low

POINTS	Compliance Date: Not Specified
2	Not In Compliance
	Violation Reference - CCR - 65529

Inspector Comments: Observed the pH at 7.2. Maintain the pH between 7.2-8.0 (ideally between 7.4-7.6).

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K429 Safety - Notification - New Sign Requirements

POINTS	Compliance Date: Not Specified
NA	Not In Compliance
	Violation Reference - CCR 24 - 3120B

Inspector Comments:

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

Unable to gain access during the time of inspection to the pump room.

Ensure the direction of water flow is provide on the recirculation system.

Photo Attachments:

No Photo Attachments