



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME WATERMAN APARTMENTS					DATE 6/19/2013	SIGNATURE
LOCATION 2634 COPPER LN, SAN BERNARDINO, CA 92408					REINSPECTION DATE 7/03/2013	PERMIT EXPIRATION 5/31/2014
MAILING ADDRESS 2634 COPPER LN, SAN BERNARDINO, CA 92408					REHS Marilyn Krichbaum	
FA # FA0012062	PR # PR0013525	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: None	
TIME IN 9:50 AM	TIME OUT 11:05 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine	
					RESULT: 05 - Corrective Action / Follow up Required	
					ACTION: 13 - Permit Suspended / Facility Closed	

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

84

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	40
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no chlorine level in the pool. Immediately add chlorine. Maintain a chlorine level of 1.5ppm not to exceed 10ppm. Observed no tablets in chlorinator. Maintain tablets in the chlorinator. Pool is closed till chlorine level is corrected. Posted closed sign. Call Marilyn at 1-800-442 2283.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

36K416 Water Quality - Non-Critical - Clarity

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed that the pool was cloudy. Main drains are visible. Make the necessary repairs.
	Not In Compliance	
	Violation Reference - CCR - 65527, 65543	

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. Under no circumstances shall the pool be used if the main drain is not clearly visible from the deck. The water of every wading pool shall be kept sufficiently clear so that the bottom of the wading pool will be visible at all times.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed a cyanuric acid level greater than 100ppm. Lower the cyanuric acid level so that it does not exceed 100ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K430 Safety - Equipment/First Aid Kit

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Provide an extension on the rescue pole. Pole must be 12ft long. Provide a rope on the life ring.
	Not In Compliance	
	Violation Reference - CCR - 65539	

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME WATERMAN APARTMENTS	DATE 6/19/2013	SIGNATURE
LOCATION 2634 COPPER LN, SAN BERNARDINO, CA 92408	REHS Marilyn Krichbaum	

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Observed no daily log of pool chlorine and ph levels. Maintain a daily log of these levels.
	Violation Reference - CCR - 65523, 65529	Obtain a 4 in 1 dpd test kit.

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

36K472 Access - Steps - Handrails - Diving Area

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Secure the loose handrails.
	Violation Reference - CCR - 3111B, 3113B	

Violation Description: Stairs shall be provided in the shallowest portion of a pool. Ladders shall be corrosion resistant and shall be equipped with slip resistant tread surfaces. Ladders shall be rigidly installed. Hand rails shall be provided at the top of both sides of each ladder and recessed steps and shall extend over the coping or edge of the deck. Diving boards and platforms shall be anchored to the pool deck, constructed of corrosion resistant material, designed and constructed to be easily cleanable and finished with a durable slip resistant material.

36K474 Lighting - Adequate Lighting and Ventilation

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Repair nonfunctioning pool light. Make sure the gfci works.
	Violation Reference - SBCC - 3115B, 3106B, 3121B	

Violation Description: Pools used at night shall be equipped with underwater lighting fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots. Pool deck areas and emergency egress areas shall be provided with lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Artificial lighting shall be provided at all spray ground pads which are used at night or which do not have adequate natural lighting so that all portions of the spray pad and deck may be seen easily.

Indoor pools, dressing rooms and toilet rooms shall be ventilated according to the requirements in Chapter 4 of the California Mechanical Code.

36K482 Restrooms - Toilet Facilities - Showers - Drinking Fountain

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Observed that one restroom, the mens restroom was locked. Provide public access. Both restrooms are required to be open for the public's use.
	Violation Reference - CCR - 65535, 65551, 3117B	Repair nonfunctioning shower. Install single service paper towel dispensers. Provide soap to dispensers.

Violation Description: Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices. Showers and lavatories shall be provided with hot and cold water faucets.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME WATERMAN APARTMENTS	DATE 6/19/2013	SIGNATURE
LOCATION 2634 COPPER LN, SAN BERNARDINO, CA 92408	REHS Marilyn Krichbaum	

36K429 Safety - Notification - New Sign Requirements

POINTS <div style="border: 1px solid black; padding: 5px; display: inline-block;"> NA </div>	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR 24 - 3120B	Inspector Comments: Provide the new pool safety signs: These signs must be in 4 inch lettering. Provide the Keep Closed sign on the exterior side of all gates. Provide the telephone number of the nearest emergency services such as the fire, ambulance, emt services. Provide the name and address of the facility in the pool area. Remove the unapproved Warning No Lifeguard on Duty Sign. Provide the pool capacity number on sign.
	<hr/> <p>Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:</p> <p>All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:</p> <p>a) Maximum number of pool users permitted for each pool. b) "NO DIVING" at pools with a maximum water depth of 6 feet or less. c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance." d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures. e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility. f) A warning sign for spa pools with "CAUTION" language. g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK." h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED." i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water. j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools. k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."</p>	

Overall Inspection Comments

Label the pool and spa filters. Provide the direction of the flow of water thru the entire recirculation system on all the piping.

Photo Attachments:
No Photo Attachments