



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**


**(800) 442-2283**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>HIGHLAND PALMS HOA</b>					DATE <b>6/20/2013</b>	SIGNATURE	
LOCATION <b>3582 20TH ST, SAN BERNARDINO, CA 92404</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>12/31/2013</b>	
MAILING ADDRESS <b>1420 N CLAREMONT BL STE 205D, CLAREMONT CA 91711</b>					REHS <b>Cecilia Jones</b>		
FA # <b>FA0007287</b>	PR # <b>PR0014666</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: pool		
TIME IN <b>9:08 AM</b>	TIME OUT <b>9:23 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 008 - Inspection - Attempted		
					RESULT: 00 - Not Applicable		
					ACTION: 00 - Not Applicable		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	69
volume (gal)	33,000
area (sq ft)	800
occupancy	40

**36K996 Attempted Inspection**

POINTS <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Facility maintenance manager stated that they will not be opening their pool until July 4th. I observed the pool to be covered, and gates locked.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** An inspection was attempted today. Another inspection will be attempted at a later date.

**36K429 Safety - Notification - New Sign Requirements**

POINTS <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b>
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments