



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>LOCH LEVEN CHRISTIAN CONF CENTER</b>					DATE <b>6/20/2013</b>	SIGNATURE	
LOCATION <b>8171 MOUNTAIN HOME CREEK RD, MENTONE, CA 92359</b>					REINSPECTION DATE <b>12/20/2013</b>	PERMIT EXPIRATION <b>12/31/2013</b>	
MAILING ADDRESS <b>36910 MILLCREEK RD, MENTONE CA 92359</b>					REHS <b>Antonio Fields</b>		
FA # <b>FA0006918</b>	PR # <b>PR0006543</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3632</b>	PROGRAM IDENTIFIER: POOL		
TIME IN <b>10:29 AM</b>	TIME OUT <b>11:13 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - ORGANIZED CAMP POOL**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**94**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	95
required flow (gpm)	85
volume (gal)	41,010
area (sq ft)	1,040
occupancy	52

**36K460 Skimmers - Requirements**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65533, 3136B

**Inspector Comments:** Observed the check valves missing in the skimmers. Provide check valves.

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**36K472 Access - Steps - Handrails - Diving Area**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3111B, 3113B

**Inspector Comments:** Loose hand rail observed in the deep end. Repair/Replace.

**Violation Description:** Stairs shall be provided in the shallowest portion of a pool. Ladders shall be corrosion resistant and shall be equipped with slip resistant tread surfaces. Ladders shall be rigidly installed. Hand rails shall be provided at the top of both sides of each ladder and recessed steps and shall extend over the coping or edge of the deck. Diving boards and platforms shall be anchored to the pool deck, constructed of corrosion resistant material, designed and constructed to be easily cleanable and finished with a durable slip resistant material.

**36K482 Restrooms - Toilet Facilities - Showers - Drinking Fountain**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65535, 65551, 3117B

**Inspector Comments:** Observed the hot and cold water missing in the restroom. Provide hot and cold water in the restroom.

Paper towel dispenser observed empty. Provide and maintain paper towels in the dispenser.

**Violation Description:** Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices. Showers and lavatories shall be provided with hot and cold water faucets.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.

**Overall Inspection Comments**



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME LOCH LEVEN CHRISTIAN CONF CENTER	DATE 6/20/2013	SIGNATURE
LOCATION 8171 MOUNTAIN HOME CREEK RD, MENTONE, CA 92359		REHS Antonio Fields

Maintain the direction of the water flow on the recirculation system.

Switch located on the circuit breaker observed capable of turning off the under water light manually. Operator uncertain if the GFCI is triggered to shut off automatically if electrical hazard occurs in the pool. Ensure functional GFCI capable of shutting off electrical power source automatically. Operator stated follow-up will be done with camp maintenance employee to determine the current function of the GFCI. Follow-up may take place within 72 hours to ensure proper operation of GFCI.

Influent pressure: 15 psi

Operator signature is located on the camp inspection.

**Photo Attachments:**

No Photo Attachments