



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

| | | | | | |
|---|-----------------------------|--------------------------------|------------------------------|--|--|
| FACILITY NAME HUNTINGTON VILLAS | | | | DATE 6/21/2013 | SIGNATURE |
| LOCATION 9741 HUNTINGTON DR, RANCHO CUCAMONGA, CA 91701 | | | | REINSPECTION DATE 12/21/2013 | PERMIT EXPIRATION 1/31/2014 |
| MAILING ADDRESS PO BOX 5022, UPLAND CA 91785 | | | | REHS Isaac Gebreslassie | |
| FA # FA0008050 | PR # PR0015078 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: Pool |
| TIME IN 10:15 AM | TIME OUT 10:35 AM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required |
| | | | | | ACTION: 01 - No Further Action Required |

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

98

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

36K460 Skimmers - Requirements

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65533,
3136B

Inspector Comments: Observed two skimmer weirs and one float assembly missing. Provide.

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:
No Photo Attachments