



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>RED HILL NORTH HOA</b>					DATE <b>6/21/2013</b>	SIGNATURE	
LOCATION <b>1500 REDHILL NORTH DR, UPLAND, CA 91786</b>					REINSPECTION DATE <b>12/21/2013</b>	PERMIT EXPIRATION <b>6/30/2013</b>	
MAILING ADDRESS <b>8599 HAVEN AV STE 201, RANCHO CUCAMONGA CA 91730</b>					REHS <b>Shannon Johnson</b>		
FA # <b>FA0008601</b>	PR # <b>PR0014408</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: west pool behind 1488		
TIME IN <b>10:30 AM</b>	TIME OUT <b>11:15 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**88**

**SCORE**

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	70
volume (gal)	25,375
area (sq ft)	590
occupancy	30

**36K990 Survey Inspection**

**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - SBCC - SBC Policy

**Inspector Comments:** Correct the following violations.

**Violation Description:** A survey inspection was conducted on this date.

**36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed the free chlorine level to be only 1ppm

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed the cyanuric acid concentration to be greater than 100ppm

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**36K444 Equipment - Recirculation Pump/Filter/Separation Tank**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC - 3120B, 3132B, 3141B

**Inspector Comments:** Observed no directional symbols on piping within the equipment enclosure.

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

(800) 442-2283

FACILITY NAME <b>RED HILL NORTH HOA</b>	DATE <b>6/21/2013</b>	SIGNATURE
LOCATION <b>1500 REDHILL NORTH DR, UPLAND, CA 91786</b>		REHS <b>Shannon Johnson</b>

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed the flow meter to be inoperable.
	Not In Compliance Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K460 Skimmers - Requirements**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no float assembly within the skimmer closest to the equipment enclosure.
	Not In Compliance Violation Reference - CCR - 65533, 3136B	

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**36K474 Lighting - Adequate Lighting and Ventilation**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed the pool light to be inoperable.
	Not In Compliance Violation Reference - SBCC - 3115B, 3106B, 3121B	

**Violation Description:** Pools used at night shall be equipped with underwater lighting fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots. Pool deck areas and emergency egress areas shall be provided with lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Artificial lighting shall be provided at all spray ground pads which are used at night or which do not have adequate natural lighting so that all portions of the spray pad and deck may be seen easily.

Indoor pools, dressing rooms and toilet rooms shall be ventilated according to the requirements in Chapter 4 of the California Mechanical Code.

**36K429 Safety - Notification - New Sign Requirements**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Update and correct all safety signs as needed.
	Not In Compliance Violation Reference - CCR 24 - 3120B	

**Violation Description:** Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**Overall Inspection Comments**

When the filter to the re-circulation system is most clean, clearly mark the initial start-up pressure on the influent gauge, in order for this department to view when the system needs to be backwashed.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME RED HILL NORTH HOA	DATE 6/21/2013	SIGNATURE
LOCATION 1500 REDHILL NORTH DR, UPLAND, CA 91786		REHS Shannon Johnson

**Photo Attachments:**

No Photo Attachments