



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

(800) 442-2283

FACILITY NAME <b>RANCHO MEADOW APARTMENTS</b>					DATE <b>6/24/2013</b>	SIGNATURE	
LOCATION <b>7401 SADDLE AV, RANCHO CUCAMONGA, CA 91730</b>					REINSPECTION DATE <b>12/24/2013</b>	PERMIT EXPIRATION <b>6/30/2013</b>	
MAILING ADDRESS <b>7401 SADDLE AV, RANCHO CUCAMONGA, CA 91730</b>					REHS <b>Isaac Gebreslassie</b>		
FA # <b>FA0006183</b>	PR # <b>PR0015385</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: spa		
TIME IN <b>10:54 AM</b>	TIME OUT <b>11:13 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**98**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

<b>Ideal</b>
<b>In Compliance</b>
<b>Not in Compliance</b>



temperature (F)	101.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid level too high. Adjust to 100 ppm or below.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments