



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**


(800) 442-2283

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>WEST COLONY COMM ASSOC</b>				DATE <b>6/24/2013</b>	SIGNATURE 
LOCATION <b>2656 LIBERTY, SAN BERNARDINO, CA 92404</b>				REINSPECTION DATE <b>11/24/2013</b>	PERMIT EXPIRATION <b>6/30/2013</b>
MAILING ADDRESS <b>PO BOX 11179, SAN BERNARDINO CA 92423</b>				REHS <b>Marilyn Krichbaum</b>	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: Pool on 1/2 Liberty	
FA # <b>FA0002889</b>	PR # <b>PR0015507</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	SERVICE: 003 - Inspection - Follow Up Inspection
TIME IN <b>4:12 PM</b>	TIME OUT <b>4:35 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 15 - Permit Reinstated / Facility Re-opened

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K994 Reinspection**

POINTS <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Reinspection: Observed that both gates now are self latching and self closing. Pool can be reopened.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**  
No Photo Attachments