



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME FAIRWAY COURT HOA					DATE 6/25/2013	SIGNATURE	
LOCATION 27535 LAKEVIEW DR, HELENDALE, CA 92342					REINSPECTION DATE 12/25/2013	PERMIT EXPIRATION 7/31/2013	
MAILING ADDRESS 12176 INDUSTRIAL BL UNIT 1, VICTORVILLE CA 92393					REHS Kathy Taylor		
FA # FA0008109	PR # PR0014634	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Spa		
TIME IN 10:35 AM	TIME OUT 11:00 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	99.0
observed flow (gpm)	No Data
required flow (gpm)	117
volume (gal)	3,500
area (sq ft)	144
occupancy	14

36K438 Enclosure - Critical - Gates Drowning Hazard

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 3119B

Inspector Comments: See pool report for door knob requirements for exit from pool area.

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Lower cyanuric acid level in spa to less than 100 ppm; drain a little water out of spa, then retest to ensure level is below 100 ppm.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K456 Maintenance - Spa/Pool Area - Pump Room

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65535

Inspector Comments: Repair small water leak at spa filter; water dripping onto concrete and exiting enclosure.

Violation Description: All parts of the pool and related pool facilities and equipment shall be maintained in good repair. Floors shall be kept free from cracks and other defects. Walls, ceilings, partitions, doors and similar surfaces and equipment shall be refinished in a manner acceptable to DEHS as often as necessary to be kept in a state of good repair. Hoses shall be provided for regular flushing and cleaning. The whole pool area shall be kept clean, sanitary and free of litter and vermin.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME FAIRWAY COURT HOA	DATE 6/25/2013	SIGNATURE
LOCATION 27535 LAKEVIEW DR, HELENDALE, CA 92342		REHS Kathy Taylor

Spa inspection today.

Check and repair (if necessary) flowmete; unable to read to get correct flow. Ensure flowmeter is operable and showing a flow of about 117 gallons per minute turnover rate.

See pool report for new sign requirements for next pool season.

NOTE: pH found at lowest legal limit today (7.2) and chlorine found too high at 10 ppm. Raise pH and lower chlorine so water chemistry is balanced. Call pool service at once to correct.

Prior to spa remodel, contact DEHS Plan check at 1-800-442-2283.

Thank you

Photo Attachments:

No Photo Attachments