



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>GOOD NITE INN</b>				DATE <b>6/25/2013</b>	SIGNATURE 
LOCATION <b>1675 INDUSTRIAL PARK AV, REDLANDS, CA 92374</b>				REINSPECTION DATE <b>12/25/2013</b>	PERMIT EXPIRATION <b>6/30/2013</b>
MAILING ADDRESS <b>1675 INDUSTRIAL PARK AV, REDLANDS, CA 92374</b>				REHS <b>Marilyn Krichbaum</b>	
FA # <b>FA0004817</b>	PR # <b>PR0015220</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: spa
TIME IN <b>2:10 PM</b>	TIME OUT <b>2:45 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**92**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	6

**36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed no chlorine level in the spa. Immediately add chlorine. Maintain a chlorine level of 1.5ppm not to exceed 10ppm. Observed tablets in the chlorinator. Check chlorinator to make sure it is working properly. Employee is making the adjustments. Management already has spa closed. Make sure the chlorine is within requirements before opening it.

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed a cyanuric acid level greater than 100ppm. Lower the cyanuric acid level so that it does not exceed 100ppm.

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**36K448 Equipment - Flow Meter**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3125B

**Inspector Comments:** Repair/replace nonfunctioning flowmeter.

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K466 Structure - Pool Shell**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3108B

**Inspector Comments:** Observed that the shell on the spa was chipped and rough. Start budgeting for replastering the spa.

Manager states that spa is going to be demolished.

**Violation Description:** The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>GOOD NITE INN</b>	DATE <b>6/25/2013</b>	SIGNATURE 
LOCATION <b>1675 INDUSTRIAL PARK AV, REDLANDS, CA 92374</b>	REHS <b>Marilyn Krichbaum</b>	

**36K429 Safety - Notification - New Sign Requirements**

<b>POINTS</b>  <div style="border: 1px solid black; padding: 5px; display: inline-block;"> <b>NA</b> </div>	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR 24 - 3120B	<b>Inspector Comments:</b> Provide the new pool safety signs: These signs must be in 4 inch lettering. Provide the Keep Closed sign on the exterior side of all gates. Provide the telephone number of the nearest emergency services such as the fire, ambulance, emt services. Provide the name and address of the facility in the pool area. The wording on the Warning No Lifeguard on Duty sign has changed. Provide the diarrhea warning sign on the gate or entrance area of the pool. This sign can be in 1 inch lettering.
---	---	---

**Violation Description:** Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**Overall Inspection Comments**

Identify the filters. Provide the direction of the flow of the water thru the entire recirculation system.

**Photo Attachments:**

No Photo Attachments