



County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | | | | | | |
|--|-----------------------------|--------------------------------|------------------------------|-------------------|--|---------------------------------------|--|
| FACILITY NAME LAS PALMAS APARTMENTS 2 | | | | | DATE 6/26/2013 | SIGNATURE | |
| LOCATION 1680 W RIALTO AV, FONTANA, CA 92335 | | | | | REINSPECTION DATE 7/10/2013 | PERMIT EXPIRATION 2/28/2014 | |
| MAILING ADDRESS 8150 COTTONWOOD AV, FONTANA CA 92335 | | | | | REHS Sierra Clayborn | | |
| FA # FA0004416 | PR # PR0013782 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: Spa SERVICE: 001 - Inspection - Routine | | |
| TIME IN 10:25 AM | TIME OUT 10:59 AM | CONTACT Not Captured | | | RESULT: 05 - Corrective Action / Follow up Required ACTION: 13 - Permit Suspended / Facility Closed | | |

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

84

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | 76.3 |
| observed flow (gpm) | No Data |
| required flow (gpm) | 19 |
| volume (gal) | 554 |
| area (sq ft) | 25 |
| occupancy | 3 |

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: Spa permit suspended due to excessively high levels of chlorine.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed chlorine exceeding 20ppm.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K442 Equipment - Critical - Non-Functioning Recirculation System

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65525

Inspector Comments: Observed poorly functioning recirculation system and emergency shut off switch.

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | |
|--|--------------------------------|-----------|
| FACILITY NAME LAS PALMAS APARTMENTS 2 | DATE 6/26/2013 | SIGNATURE |
| LOCATION 1680 W RIALTO AV, FONTANA, CA 92335 | REHS Sierra Clayborn | |

36K428 Safety - Safety Signs

| | | |
|--------------------------------------|--------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed missing Emergency Shut Off sign. |
| | Not In Compliance | |
| Violation Reference - CCR 24 - 3120B | | |

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K448 Equipment - Flow Meter

| | | |
|-----------------------------------|--------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed broken flow meter. |
| | Not In Compliance | |
| Violation Reference - CCR - 3125B | | |

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K460 Skimmers - Requirements

| | | |
|--|--------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed little to no suction from skimmer. Ensure skimmer is producing 75% suction compared to main drain at 25% suction. Observed excessive debris in skimmer and film on skimmer surface. |
| | Not In Compliance | |
| Violation Reference - CCR - 65533, 3136B | | |

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

36K474 Lighting - Adequate Lighting and Ventilation

| | | |
|--|--------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed non-functioning GFCI and light. Observed water in pool light fixture. |
| | Not In Compliance | |
| Violation Reference - SBCC - 3115B, 3106B, 3121B | | |

Violation Description: Pools used at night shall be equipped with underwater lighting fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots. Pool deck areas and emergency egress areas shall be provided with lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Artificial lighting shall be provided at all spray ground pads which are used at night or which do not have adequate natural lighting so that all portions of the spray pad and deck may be seen easily.

Indoor pools, dressing rooms and toilet rooms shall be ventilated according to the requirements in Chapter 4 of the California Mechanical Code.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments