



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME COURTYARD BY MARRIOTT					DATE 7/1/2013	SIGNATURE <i>Reel</i>	
LOCATION 9619 MARIPOSA RD, HESPERIA, CA 92345					REINSPECTION DATE 1/01/2014	PERMIT EXPIRATION 11/30/2013	
MAILING ADDRESS 3023 E. ANDY DEVINE AV , KINGMAN AZ 86401					<input type="checkbox"/> FACILITY <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT REHS John Ramos		
FA # FA0016658	PR # PR0022227	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Indoor pool		
TIME IN 11:04 AM	TIME OUT 11:35 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	65
required flow (gpm)	25
volume (gal)	8,800
area (sq ft)	315
occupancy	15

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Comply by: 7/15/2013
Not In Compliance
Violation Reference - HSC

Inspector Comments: Permit is suspended and pool is hereby ordered closed due to high chlorine. Notice of closure sign posted. Do not remove sign or reopen pool without authorization from Environmental Health. Contact John Ramos at (800) 442-2283 when pool is ready to reopen.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS
4

Comply by: 7/15/2013
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed free chlorine above 10 ppm. Ensure to maintain free chlorine between 1.5 to 10.0 ppm. Pool closed due to high chlorine level.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME COURTYARD BY MARRIOTT	DATE 7/1/2013	SIGNATURE <i>John Ramos</i>
LOCATION 9619 MARIPOSA RD, HESPERIA, CA 92345	REHS John Ramos	

36K429 Safety - Notification - New Sign Requirements

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed safety signs are outdated and should be replaced within 1 year.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

Permit is suspended and pool is hereby ordered closed due to high chlorine. Notice of closure sign posted. Do not remove sign or reopen pool without authorization from Environmental Health.

Correct the above noted violations.

Contact John Ramos at (800) 442-2283 when pool is ready to reopen.

Photo Attachments:

No Photo Attachments