



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT




(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME COURTYARD BY MARRIOTT				DATE 7/1/2013	SIGNATURE <i>John Ramos</i>
LOCATION 9619 MARIPOSA RD, HESPERIA, CA 92345				REINSPECTION DATE 12/01/2013	PERMIT EXPIRATION 11/30/2013
MAILING ADDRESS 3023 E. ANDY DEVINE AV, KINGMAN AZ 86401				REHS John Ramos	
FA # FA0016658	PR # PR0022227	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Indoor pool
TIME IN 2:42 PM	TIME OUT 2:57 PM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection
					RESULT: 01 - Corrective Action Not Required
					ACTION: 15 - Permit Reinstated / Facility Re-opened

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	65
required flow (gpm)	25
volume (gal)	8,800
area (sq ft)	315
occupancy	15

36K992 Permit Reinstatement

POINTS
NA

Compliance Date: Not Specified
 Complied on 7/1/2013
 Violation Reference - HSC

Inspector Comments: Permit is hereby reinstated. A reinspection was conducted to determine compliance with previously observed violations that have been corrected.

Pool is reopened.

Violation Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS
NA

Compliance Date: Not Specified
 Complied on 7/1/2013
 Violation Reference - HSC

Inspector Comments: Reinspection conducted to determine compliance with previously observed violations from a previous inspection. The high chlorine has been corrected.

Pool is reopened.

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Reinspection conducted to determine compliance with previously observed violations from a previous inspection. The low chlorine has been corrected.

Health permit is hereby reinstated.

Pool is reopened.

If you have any questions contact John Ramos at (800) 442-2283.
 Our office has moved to 15900 Smoke Tree Street, Hesperia, CA 92345.

Photo Attachments:

No Photo Attachments