



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT



(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME RED ROOF INN ONTARIO AIRPORT				DATE 7/1/2013	SIGNATURE
LOCATION 1818 E HOLT BL, ONTARIO, CA 91761				REINSPECTION DATE 12/01/2013	PERMIT EXPIRATION 12/31/2013
MAILING ADDRESS 1801 S RAINBOW BL UNIT 270, LAS VEGAS NV 89146				<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Sierra Clayborn	
FA # FA0005771	PR # PR0015935	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 4:53 PM	TIME OUT 5:05 PM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 15 - Permit Reinstated / Facility Re-opened

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	43
volume (gal)	15,420
area (sq ft)	589
occupancy	20

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: During routine inspection, pool was closed for lack of chlorine. Reinspection performed to confirm compliance with disinfectant requirement.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Observed chlorine at 3.5ppm and pH at 7.2.
 Pool permit reinstated and open for use.

Photo Attachments:
 No Photo Attachments