



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>BRIGHTON AT TERRA VISTA HOA</b>				DATE <b>7/3/2013</b>	SIGNATURE
LOCATION <b>11450 CHURCH ST, RANCHO CUCAMONGA, CA 91730</b>				REINSPECTION DATE <b>1/03/2014</b>	PERMIT EXPIRATION <b>2/28/2014</b>
MAILING ADDRESS <b>195 N EUCLID AV, UPLAND CA 91785</b>				REHS <b>Isaac Gebreslassie</b>	
FA # <b>FA0014424</b>	PR # <b>PR0019058</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Spa
TIME IN <b>1:48 PM</b>	TIME OUT <b>2:12 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**98**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	102.8
observed flow (gpm)	45
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	6

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - CCR - 65529

**Inspector Comments:** Observed cyanuric acid level too high.

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments