



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**




(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME EUREKA MANOR				DATE 7/5/2013	SIGNATURE	
LOCATION 1525 E EUREKA ST, SAN BERNARDINO, CA 92404				REINSPECTION DATE 12/05/2013	PERMIT EXPIRATION 3/31/2014	
MAILING ADDRESS 4900 SANTA ANITA AV UNIT 2C, EL MONTE CA 91731				<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Sierra Clayborn		
FA # FA0008381	PR # PR0015659	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: pool	
TIME IN 9:50 AM	TIME OUT 10:01 AM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection	
					RESULT: 03 - Corrective Action / No Follow up Required	
					ACTION: 15 - Permit Reinstated / Facility Re-opened	

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	57
volume (gal)	20,655
area (sq ft)	648
occupancy	32

36K994 Reinspection

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: During routine inspection, permit was suspended due to unsecured gate with missing slats.

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Observed gate with new welding on several slats. Observed some parts of gate with excessive rust that needs to be addressed immediately.
Observed gate secure.
Permit reinstated, pool area open for use.

Photo Attachments:
No Photo Attachments