



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

| | | | | | |
|--|-----------------------------|--------------------------------|------------------------------|---------------------------------------|--|
| FACILITY NAME CREEKSIDE WEST VILLAGE | | | | DATE 7/8/2013 | SIGNATURE |
| LOCATION 2802 DEER CREEK LOOP, ONTARIO, CA 91761 | | | | REINSPECTION DATE 1/08/2014 | PERMIT EXPIRATION 2/28/2014 |
| MAILING ADDRESS 9267 HAVEN AV STE 235, RANCHO CUCAMONGA CA 91730 | | | | REHS Hanan Megalla | |
| FA # FA0005777 | PR # PR0014951 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: Pool at The Landing APTS |
| TIME IN 10:12 AM | TIME OUT 10:32 AM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required |
| | | | | | ACTION: 01 - No Further Action Required |

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

36K448 Equipment - Flow Meter

| | |
|---------------|-----------------------------------|
| POINTS | Compliance Date: Not Specified |
| 2 | Not In Compliance |
| | Violation Reference - CCR - 3125B |

Inspector Comments: Replace or repair stuck inoperable flow meter for pool circulation.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K460 Skimmers - Requirements

| | |
|---------------|--|
| POINTS | Compliance Date: Not Specified |
| 2 | Not In Compliance |
| | Violation Reference - CCR - 65533, 3136B |

Inspector Comments: Replace broken float assembly for all of the pool skimmers.

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

36K466 Structure - Pool Shell

| | |
|---------------|-----------------------------------|
| POINTS | Compliance Date: Not Specified |
| 2 | Not In Compliance |
| | Violation Reference - CCR - 3108B |

Inspector Comments: Replace the broken tiles on the side of pool shell.

Violation Description: The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | |
|---|------------------------------|-----------|
| FACILITY NAME CREEKSIDE WEST VILLAGE | DATE 7/8/2013 | SIGNATURE |
| LOCATION 2802 DEER CREEK LOOP , ONTARIO, CA 91761 | REHS Hanan Megalla | |

36K429 Safety - Notification - New Sign Requirements

| | | |
|----------------------------|--------------------------------------|--|
| POINTS NA | Compliance Date: Not Specified | Inspector Comments: Provide all required signs. |
| | Not In Compliance | |
| | Violation Reference - CCR 24 - 3120B | |

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments