



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**




(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME DELMAN HEIGHTS POOL				DATE 7/8/2013	SIGNATURE	
LOCATION 2969 FLORES ST, SAN BERNARDINO, CA 92405				REINSPECTION DATE 12/08/2013	PERMIT EXPIRATION 9/30/2013	
MAILING ADDRESS 1350 S E ST, SAN BERNARDINO CA 92408-2725				REHS Breyanna Lyles		
FA # FA0006499	PR # PR0016981	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: None	
TIME IN 2:01 PM	TIME OUT 2:19 PM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection	
					RESULT: 01 - Corrective Action Not Required	
					ACTION: 15 - Permit Reinstated / Facility Re-opened	

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	168

No Violations Cited

Overall Inspection Comments

During follow-up inspection, measured chlorine in pool at 1.5ppm. Pool now meets required chlorine levels and can be re-opened.

Photo Attachments:

No Photo Attachments