



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>24 HOUR FITNESS</b>				DATE <b>7/9/2013</b>	SIGNATURE
LOCATION <b>4200 CHINO HILLS PKWY 780, CHINO HILLS, CA 91709</b>				REINSPECTION DATE <b>1/09/2014</b>	PERMIT EXPIRATION <b>3/31/2014</b>
MAILING ADDRESS <b>PO BOX 2409, CARLSBAD CA 92018</b>				REHS <b>Tin Nguyen</b>	
FA # <b>FA0014012</b>	PR # <b>PR0018513</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: pool
TIME IN <b>3:26 PM</b>	TIME OUT <b>4:00 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**98**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	50
required flow (gpm)	139
volume (gal)	50,200
area (sq ft)	1,575
occupancy	78

**36K460 Skimmers - Requirements**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65533, 3136B

**Inspector Comments:**  
-Observed three out of four weir gate in skimmers. Repair/replace.  
**NOTE:**  
-Per operator, weir gate is ordered.

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**Overall Inspection Comments**

pH: 7.2  
Chlorine: 10.0 ppm  
CYA: < 30 ppm  
Flow rate: 50 gpm

Capacity: 50,200 gal  
Flow rate: 139 gpm  
Surface area: 1,575 sq ft  
Occupancy: 78

**Photo Attachments:**  
No Photo Attachments