



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME MCDONALD'S #10023				DATE 7/10/2013	SIGNATURE <i>Dawn LaFlower</i>
LOCATION 12146 MARIPOSA RD, VICTORVILLE, CA 92392				REINSPECTION DATE Not Specified	PERMIT EXPIRATION
MAILING ADDRESS 12146 MARIPOSA RD, VICTORVILLE, CA 92392				REHS Dawn LaFlower	
FA # FA0005790	PR # Not Specified	SR # Not Specified	CO # CO0045120	PE 1622	PROGRAM IDENTIFIER: None
TIME IN 4:37 PM	TIME OUT 4:52 PM	CONTACT Not Captured			SERVICE: 013 - Food - Billable Inspection Services
					RESULT: 01 - Corrective Action Not Required
					ACTION: 01 - No Further Action Required

**RETAIL FOOD PROTECTION - PUBLIC EATING PL (100-UP SEATS)**

**16K993 Re-Reinspection**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

**Inspector Comments:** This charged reinspection is being conducted to determine compliance regarding the hot water supply in women restroom. Last reinspection was conducted on 6/26/2013. Operator was to contact Environmental Health when repaired.

**Violation Description:** Billable re-reinspection conducted at this time to determine compliance from prior reinspection.

**Overall Inspection Comments**

Observed repairs made to plumbing in womens restroom. Maximum warm water temperature through hot water valve at 103 degrees. Observed cold water through cold water valve.

Complaint closed.

**Photo Attachments:**  
No Photo Attachments