



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>ASPEN CLUBHOUSE</b>				DATE 7/11/2013	SIGNATURE <i>D. Stewart</i>
LOCATION 10741 LAKESHORE DR, APPLE VALLEY, CA 92308				REINSPECTION DATE 1/11/2014	PERMIT EXPIRATION 10/31/2013
MAILING ADDRESS 19311 JESS RANCH PKWY, APPLE VALLEY CA 92308				REHS Dawn LaFlower	
FA # FA0014985	PR # PR0019814	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: outdoor small pool
TIME IN 2:53 PM	TIME OUT 3:18 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**96**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	75
required flow (gpm)	62
volume (gal)	22,530
area (sq ft)	707
occupancy	35

**36K406 Water Quality - Critical - pH High/Low**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	Inspector Comments: Maintain pH between 7.2-8.0. Ideal is 7.4-7.6.
	Not In Compliance	Observed pH measuring below 7.0. Corrected to 7.4.
	Violation Reference - CCR - 65529	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments