



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME WIGWAM MOTEL				DATE 7/11/2013	SIGNATURE
LOCATION 2728 W FOOTHILL BL, SAN BERNARDINO, CA 92410				REINSPECTION DATE 12/11/2013	PERMIT EXPIRATION 11/30/2013
MAILING ADDRESS 2728 W FOOTHILL BL, RIALTO CA 92376				REHS Breyanna Lyles	
FA # FA0013368	PR # PR0017704	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: None
TIME IN 4:56 PM	TIME OUT 5:04 PM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 15 - Permit Reinstated / Facility Re-opened

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	50
volume (gal)	12,400
area (sq ft)	420
occupancy	10

36K992 Permit Reinstatement

<table border="1"> <tr><td>POINTS</td></tr> <tr><td align="center">NA</td></tr> </table>	POINTS	NA	Compliance Date: Not Specified	Inspector Comments: During routine inspection, measured chlorine at 0ppm. During follow-up inspection chlorine measured 3.5ppm. Permit is re-instated and pool can be re-opened.
	POINTS			
	NA			
Not In Compliance				
Violation Reference - HSC				

Violation Description: The health permit to operate is hereby reinstated and facility may open.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments