



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME NOVA VILLAGE GREEN					DATE 7/11/2013	SIGNATURE <i>[Signature]</i>
LOCATION 2122 W CHESTNUT ST, SAN BERNARDINO, CA 92410					REINSPECTION DATE 1/11/2014	PERMIT EXPIRATION 8/31/2013
MAILING ADDRESS 2122 W CHESTNUT ST, SAN BERNARDINO, CA 92410					REHS John Babalola	
FA # FA0008825	PR # PR0016009	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool	
TIME IN 5:13 PM	TIME OUT 5:48 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine	
					RESULT: 03 - Corrective Action / No Follow up Required	
					ACTION: 01 - No Further Action Required	

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

88

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	0
required flow (gpm)	132
volume (gal)	47,520
area (sq ft)	1,152
occupancy	57

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: The cyanuric acid level is observed above 100 ppm.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K428 Safety - Safety Signs

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR 24 - 3120B

Inspector Comments: No capacity number indicated.
No capacity number observed.

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME NOVA VILLAGE GREEN	DATE 7/11/2013	SIGNATURE <i>John Babalola</i>
LOCATION 2122 W CHESTNUT ST, SAN BERNARDINO, CA 92410	REHS John Babalola	

36K434 Supervision - Lifeguards

POINTS 2	Compliance Date: Not Specified	Inspector Comments: No attached rope observed on the life ring.
	Not In Compliance	
Violation Reference - HSC - 65521, 65537, 116033...		

Violation Description: Every pool shall be under the supervision of a person who is fully capable of, and shall assume responsibility for, compliance with all requirements relating to pool operation, maintenance and safety of bathers.

Persons providing aquatic instruction shall possess current certificates from an American Red Cross or YMCA of the U.S.A. lifeguard training program, or have equivalent qualifications, as determined by DEHS. In addition, these persons shall be certified in standard first aid and cardiopulmonary resuscitation (CPR).

Lifeguard service shall be provided for any public swimming pool that is of wholly artificial construction and for the use of which a direct fee is charged. The number of lifeguards shall be adequate to maintain continuous surveillance over the bathers. For all other public swimming pools, lifeguard service shall be provided or signs shall be erected clearly indicating that the service is not provided.

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Repair/replace the non-functional flow meter.
	Not In Compliance	
Violation Reference - CCR - 3125B		

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified	Inspector Comments: No daily records of pH and chlorine readings observed.
	Not In Compliance	
Violation Reference - CCR - 65523, 65529		

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

36K460 Skimmers - Requirements

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Replace the missing skimmer wier gates.
	Not In Compliance	
Violation Reference - CCR - 65533, 3136B		

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME NOVA VILLAGE GREEN	DATE 7/11/2013	SIGNATURE
LOCATION 2122 W CHESTNUT ST, SAN BERNARDINO, CA 92410	REHS John Babalola	

36K429 Safety - Notification - New Sign Requirements

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Required safety signs.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments