



County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME MISSIONS AT CHINO HILLS LP				DATE 7/12/2013	SIGNATURE
LOCATION 3100 CHINO HILLS PKWY, CHINO HILLS, CA 91709				REINSPECTION DATE 1/12/2014	PERMIT EXPIRATION 7/31/2013
MAILING ADDRESS PO BOX 7653, MERRIFIELD VA 22116-7653				REHS Tin Nguyen	
FA # FA0010609	PR # PR0014100	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Spa
TIME IN 2:50 PM	TIME OUT 3:06 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

90

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	66
volume (gal)	2,000
area (sq ft)	100
occupancy	10

36K416 Water Quality - Non-Critical - Clarity

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed spa water cloudy; however maintain drain is still visible.
	Not In Compliance	
	Violation Reference - CCR - 65527, 65543	

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. Under no circumstances shall the pool be used if the main drain is not clearly visible from the deck. The water of every wading pool shall be kept sufficiently clear so that the bottom of the wading pool will be visible at all times.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid level above 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	Observed flow meter stuck. Repair/replace.
	Violation Reference - CCR - 3125B	NOTE: -Maintain flow rate at 66 gpm.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed spa/pool record missing for July. Provide update records of spa chemical.
	Not In Compliance	
	Violation Reference - CCR - 65523, 65529	

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

<small>FACILITY NAME</small> MISSIONS AT CHINO HILLS LP	<small>DATE</small> 7/12/2013	<small>SIGNATURE</small>
<small>LOCATION</small> 3100 CHINO HILLS PKWY, CHINO HILLS, CA 91709	<small>REHS</small> Tin Nguyen	

36K460 Skimmers - Requirements

POINTS 2	<small>Compliance Date: Not Specified</small> <small>Not In Compliance</small> <small>Violation Reference - CCR - 65533, 3136B</small>	<small>Inspector Comments: Observed one the skimmer basket torn. Repair/replace.</small>
-------------------------------	--	--

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

Overall Inspection Comments

pH: 7.2
 Chlorine: 1.5 ppm
 CYA: > 100 ppm
 Flow rate: n/a

Photo Attachments:
 No Photo Attachments