



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME STONEBROOK ESTATES				DATE 7/15/2013	SIGNATURE
LOCATION 19292 KANBRIDGE ST, APPLE VALLEY, CA 92308				REINSPECTION DATE 1/15/2014	PERMIT EXPIRATION 7/31/2013
MAILING ADDRESS PO BOX 294326, PHELAN CA 92329				REHS Dawn LaFlower	
FA # FA0000544	PR # PR0015890	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: pool
TIME IN 10:09 AM	TIME OUT 10:33 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required


RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	72
volume (gal)	26,079
area (sq ft)	734
occupancy	34

36K438 Enclosure - Critical - Gates Drowning Hazard

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Repair gate from tennis court to entrance to pool area to self close and self latch.
	Not In Compliance	Observed gate maintained open by stuck on concrete walkway. Corrected.
	Violation Reference - HSC - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Ensure cyanuric acid concentration does not exceed 100 ppm.
	Not In Compliance	Observed exceeding 100 ppm.
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K452 Maintenance - Turnover Time

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Ensure pool has a minimum turnover time of 6 hours.
	Not In Compliance	Observed a flow rate of 50 gpm. The minimum flow rate for this pool is 72 gpm. Recommend backwashing system and cleaning filter grids.
	Violation Reference - CCR 24 - 3124B	

Violation Description: The recirculation system shall have the capacity to provide a complete turnover of pool water in:

1. One-half hour or less for a spa pool;
2. One-half hour or less for a spray ground;
3. One hour or less for a wading pool;
4. Two hours or less for a medical pool; and
5. Six hours or less for all other types of public pools.

Overall Inspection Comments

Please contact Dawn La Flower at 800-442-2283 to discuss inspection reports and provide email address to send inspection reports on a timely basis.

Photo Attachments:
No Photo Attachments