



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>VILLAGE OAKS APARTMENTS</b>					DATE <b>7/16/2013</b>	SIGNATURE	
LOCATION <b>15773 HIGH KNOLL DR, CHINO HILLS, CA 91709</b>					REINSPECTION DATE <b>1/16/2014</b>	PERMIT EXPIRATION <b>6/30/2014</b>	
MAILING ADDRESS <b>15773 HIGH KNOLL DR, CHINO HILLS, CA 91709</b>					REHS <b>Tin Nguyen</b>		
FA # <b>FA0005109</b>	PR # <b>PR0015983</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Spa - South		
TIME IN <b>10:29 AM</b>	TIME OUT <b>10:54 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**90**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	102.0
observed flow (gpm)	70
required flow (gpm)	68
volume (gal)	2,050
area (sq ft)	78
occupancy	8

**36K404 Water Quality - Critical - High Disinfectant Level**

**⚠ CRITICAL ⚠**

**POINTS**  
**4**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:**  
-Observed chlorine level above 20 ppm.  
  
Corrective action:  
-Maintenance was present at time of inspection, and chlorine level was lowered to 10.0 ppm.

**Violation Description:** Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

**36K414 Water Quality - Non-Critical - pH High/Low**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed pH level at 7.0.

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed cyanuric acid level above 100 ppm.

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**36K466 Structure - Pool Shell**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3108B

**Inspector Comments:** Observed spa shell chipped. Ensure spa shell is smooth and non-abrasive.

**Violation Description:** The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.

**Overall Inspection Comments**

pH: 7.0  
Chlorine: 20.0 ppm -> 10.0 ppm  
CYA: > 100 ppm  
Flow rate: 70 gpm



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>VILLAGE OAKS APARTMENTS</b>	DATE <b>7/16/2013</b>	SIGNATURE
LOCATION <b>15773 HIGH KNOLL DR, CHINO HILLS, CA 91709</b>		REHS <b>Tin Nguyen</b>

**Photo Attachments:**

No Photo Attachments