



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME FAIRFIELD INN & SUITES TWENTYNINE PALMS					DATE 7/16/2013	SIGNATURE	
LOCATION 6333 ENCELIA AV, TWENTYNINE PALMS, CA 92277					REINSPECTION DATE 7/30/2013	PERMIT EXPIRATION 7/31/2013	
MAILING ADDRESS 6333 ENCELIA AV, TWENTYNINE PALMS CA 92277					REHS Chaz Harrison		
FA # FA0017224	PR # PR0023287	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool		
TIME IN 10:54 AM	TIME OUT 11:44 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 13 - Permit Suspended / Facility Closed		

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65529

Inspector Comments: Observed chlorine level at +20 ppm. Immediately bring chlorine level within 1.5-10 ppm.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K406 Water Quality - Critical - pH High/Low

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65529

Inspector Comments: Observed pH level above 8.0. Ensure to bring pH level between 7.2-8.0. Use Muriatic Acid to decrease the Total Alkalinity of pool. Corrected on Site.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments