



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT



(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME RADISSON ONTARIO AIRPORT				DATE 7/16/2013	SIGNATURE
LOCATION 2200 E HOLT BL, ONTARIO, CA 91761				REINSPECTION DATE 12/16/2013	PERMIT EXPIRATION 8/31/2013
MAILING ADDRESS 2155 E CONVENTION CENTER WY, ONTARIO CA 91764				REHS Sierra Clayborn	
FA # FA0006518	PR # PR0013910	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Spa
TIME IN 12:15 PM	TIME OUT 12:46 PM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K992 Permit Reinstatement

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC

Inspector Comments:

Violation Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC

Inspector Comments: During routine inspection, observed chlorine at 16ppm.

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Observed chlorine initially at 0.5ppm.
 After shock treatment, chlorine measured at 4.5ppm.

Spa permit reinstated; pool area open for use.

Photo Attachments:

No Photo Attachments