



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | | | | | | |
|---|----------------------------|--------------------------------|------------------------------|-------------------|--|---------------------------------------|--|
| FACILITY NAME MOTEL 6 1085 | | | | | DATE 7/17/2013 | SIGNATURE | |
| LOCATION 72562 29 PALMS HWY, TWENTYNINE PALMS, CA 92277 | | | | | REINSPECTION DATE 1/17/2014 | PERMIT EXPIRATION 9/30/2013 | |
| MAILING ADDRESS PO BOX 117508, CARROLLTON TX 75011-7508 | | | | | <input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Chaz Harrison | | |
| FA # FA0006785 | PR # PR0015450 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: spa | | |
| TIME IN 1:20 PM | TIME OUT 1:38 PM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine | | |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required | | |
| | | | | | ACTION: 01 - No Further Action Required | | |

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 43 |
| volume (gal) | 1,305 |
| area (sq ft) | 58 |
| occupancy | 6 |

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65529

Inspector Comments: Observed chlorine level at +20 ppm. Immediately bring chlorine level within 1.5-10 ppm. Corrected on site.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid level above 100 ppm. Cyanuric acid shall not exceed 100 ppm. Cyanuric acid can be lowered by slightly draining the pool/spa and adding fresh water.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments