



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME PROMONTORY				DATE 7/17/2013	SIGNATURE
LOCATION 13156 PINNACLE CT, CHINO HILLS, CA 91709				REINSPECTION DATE 1/17/2014	PERMIT EXPIRATION 8/31/2013
MAILING ADDRESS 132 S ANITA DR STE 200, ORANGE CA 92868				REHS Tin Nguyen	
FA # FA0007322	PR # PR0014641	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 2:42 PM	TIME OUT 3:12 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

98

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	60
required flow (gpm)	87
volume (gal)	31,567
area (sq ft)	993
occupancy	50

36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level

POINTS
2

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65529

Inspector Comments:
 -Observed chlorine level at 1.0 ppm in pool.

NOTE:
 -Cyanuric acid level at 30 ppm.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

Overall Inspection Comments

pH: 7.4
 Chlorine: 1.0 ppm
 CYA: 30 ppm
 Flow rate: 60 gpm

Capacity: 31, 567 gal
 Flow rate: 87
 Surface area: 993
 Occupancy: 50

Photo Attachments:
 No Photo Attachments