



County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME CENTURY VILLAGE RIALTO EAST					DATE 7/17/2013	SIGNATURE	
LOCATION 588 W VIRGINIA DR, RIALTO, CA 92377					REINSPECTION DATE 7/31/2013	PERMIT EXPIRATION 6/30/2014	
MAILING ADDRESS 14780 PIPELINE AV, CHINO HILLS CA 91709					REHS Breyanna Lyles		
FA # FA0008367	PR # PR0014597	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool SERVICE: 001 - Inspection - Routine		
TIME IN 3:58 PM	TIME OUT 4:43 PM	CONTACT Not Captured			RESULT: 05 - Corrective Action / Follow up Required ACTION: 14 - Permit Suspd / Facility Closed fencing iss		

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

88

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	60
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	40

36K436 Enclosure - Critical - Enclosure Drowning Hazard

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR 24 - 3119B

Inspector Comments: Observed missing bar in fence, creating an 8 inch gap in the enclosure. Maintain fencing in good condition, with no gaps or holes greater than 4 inches.

Violation Description: The pool shall be enclosed by one or a combination of the following: a fence; portion of a building; wall; or other approved durable enclosure. Doors, windows gates of living units or associated private premises shall not be permitted as part of the pool enclosure. The enclosure shall have a minimum effective perpendicular height of 5 feet. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch diameter sphere. The enclosure shall be constructed over a hard and permanent material equivalent to concrete. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children.

36K454 Maintenance - Cleanliness

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65533

Inspector Comments: Observed various debris and trash on pool deck (clothes, sleeping bag, beer bottle, sanitary pad, etc). Observed feces on ground outside of restroom. Clean and maintain pool deck.

Violation Description: Floating scum, sputum or debris shall not be allowed to accumulate in the pool. The bottom and sides of the pool shall be cleaned as often as necessary to be kept in a clean condition. The sides and bottom of pools, decks and other surfaces shall be kept free of slime and algae.

36K460 Skimmers - Requirements

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65533, 3136B

Inspector Comments: Observed missing float assembly in skimmer. Provide float assembly.

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

36K472 Access - Steps - Handrails - Diving Area

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3111B, 3113B

Inspector Comments: Observed loose handrails at both ends of pool. Fix and secure handrails.

Violation Description: Stairs shall be provided in the shallowest portion of a pool. Ladders shall be corrosion resistant and shall be equipped with slip resistant tread surfaces. Ladders shall be rigidly installed. Hand rails shall be provided at the top of both sides of each ladder and recessed steps and shall extend over the coping or edge of the deck. Diving boards and platforms shall be anchored to the pool deck, constructed of corrosion resistant material, designed and constructed to be easily cleanable and finished with a durable slip resistant material.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME CENTURY VILLAGE RIALTO EAST	DATE 7/17/2013	SIGNATURE
LOCATION 588 W VIRGINIA DR, RIALTO, CA 92377	REHS Breyanna Lyles	

36K482 Restrooms - Toilet Facilities - Showers - Drinking Fountain

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed restroom unclean and containing bad odor. Clean and maintain restrooms in good condition.
	Not In Compliance	
	Violation Reference - CCR - 65535, 65551, 3117B	

Violation Description: Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate- cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices. Showers and lavatories shall be provided with hot and cold water faucets.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.

36K995 Permit - Suspension ⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed hole in fence measuring over 8 inches. Permit has been suspended until fencing is repaired.
	Not In Compliance	
	Violation Reference -	

Violation Description:

Overall Inspection Comments

Posted "pool/spa" closed sign at main pool entrance.

Photo Attachments:

No Photo Attachments