



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>CIRCLE C</b>					DATE <b>7/18/2013</b>	SIGNATURE	
LOCATION <b>6340 EL REY AV, TWENTYNINE PALMS, CA 92277</b>					REINSPECTION DATE <b>1/18/2014</b>	PERMIT EXPIRATION <b>6/30/2014</b>	
MAILING ADDRESS <b>6340 EL REY AV, TWENTYNINE PALMS, CA 92277</b>					REHS <b>Chaz Harrison</b>		
FA # <b>FA0006149</b>	PR # <b>PR0014876</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool		
TIME IN <b>12:12 PM</b>	TIME OUT <b>12:25 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**94**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K406 Water Quality - Critical - pH High/Low**

**CRITICAL**

POINTS  
**4**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - CCR - 65529

Inspector Comments: Observed pH level at 7.0. Immediately provide pH level at 7.2-8.0. Use Soda Ash(Baking Soda) to increase the Total Alkalinity of pool.

Corrected on site.  
 p.H reading 7.2

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**36K418 Water Quality - Cyanurates**

POINTS  
**2**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid level above 100 ppm. Cyanuric acid shall not exceed 100 ppm. Cyanuric acid can be lowered by slightly draining the pool/spa and adding fresh water.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments