



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME OASIS TOWNHOUSE APARTMENTS					DATE 7/19/2013	SIGNATURE	
LOCATION 25590 PROSPECT AV, LOMA LINDA, CA 92354					REINSPECTION DATE 1/19/2014	PERMIT EXPIRATION 10/31/2013	
MAILING ADDRESS 25590 PROSPECT AV, LOMA LINDA, CA 92354					REHS Yong Aday		
FA # FA0004118	PR # PR0015355	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: office pool		
TIME IN 3:23 PM	TIME OUT 3:42 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	50

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed chlorine level at 13ppm in the pool. Pool should not be use until chlorine level is at 1.5-10ppm.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid level at above 100ppm in the pool.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

Overall Inspection Comments

- Note:
- Identify pool equipments and piping in the pump room, and mark all pipes with arrows.
 - Provide safety signs according to the new signage requirement. A letter regarding the new requirement was sent out by this dept. The information is also available on our website: www.sbcounty.gov/dph/dehs

Photo Attachments:
No Photo Attachments