



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME DESERT VISTA VILLAGE					DATE 7/18/2013	SIGNATURE	
LOCATION 7345 PALM AV, YUCCA VALLEY, CA 92284					REINSPECTION DATE 8/01/2013	PERMIT EXPIRATION 7/31/2013	
MAILING ADDRESS PO BOX 90250, HENDERSON NV 89009					REHS Dior Porter		
FA # FA0017228	PR # PR0023256	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Spa		
TIME IN 12:51 PM	TIME OUT 1:05 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 03 - Reinspection Required		

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed 50ppm chlorine. Maintain at 1.0-10ppm (with cyanuric acid 1.5ppm) Permit suspended previously and will remain suspended. Facility closure sign posted. Contact department of Environmental Health at 800-442-2283 when violation is corrected and facility is ready for reinspection.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K426 Safety - Emergency Shut-Off Switch

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed missing knob at emergency shut off switch. Repair.
	Not In Compliance	
	Violation Reference - CCR - 3138B	

Violation Description: A clearly labeled emergency shut off switch for the control of both the recirculation system and the aeration and/or jet system shall be installed adjacent to the spa pool.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments